



Manufacturers

An ISO 9001:2008 Certified

OFFLINE UPS

Offline UPS



Salient Features

- Visual indicators audio / visual indicators
- Backup time : 15-20 minutes on fully charged batteries
- Low Battery Audio Alarm
- Over Load Audio Alarm
- Low Battery Cut Off

Specifications

Parameters	Orbit UPS
Standard Models	UPS 800 UPS 1000 / UPS 1250
Rating	500 W 700 W / 900 W
Design	PWM Teachnology

ON MAINS

- Input Voltage : 160 - 270 V AC
- OUTPUT Voltage : 200 - 240 V AC
- UV Cut In : < 160 V AC

ON BATTERY

- Output Voltage : 210 V AC +/- 10%
- Battery Voltage : 24 V DC
- Output Frequency : 50Hz +/- 1%
- Transfer Time : < 5 ms
- Recharge Time : < 7 hours for output greater than 150 V AC
- Back Up Time : Depends upon Load & Batteries Type